

# ASBESTOS REGISTER

**SITE:** 7859 Green Ryde

**LAST UPDATED:** 11/09/2017

JOB NUMBER CLIENT ADDRESS

Date Identified	Location of ACM	Type	Friable / Non-Friable	Quantity	Condition	Assessment / Action
08/09/2017	Eave soffit lining	Asbestos cement sheet	Non-friable	13 sqm	Good/Stable Surface coated to the exposed areas	Protect the retained ACM from damage during the course of the works
08/09/2017	Behind gable end cladding	Asbestos cement sheet	Non-friable	15.5 sqm	Good/Stable Surface coated to the exposed areas	Protect the retained ACM from damage during the course of the works
08/09/2017	Front porch soffit lining and infill panel	Asbestos cement sheet	Non-friable	7 sqm	Good/Stable Surface coated to the exposed areas	Protect the retained ACM from damage during the course of the works