

# ASBESTOS REGISTER

**SITE:** 7883      Wolff      80 Balfour Road, Bellevue Hill

**LAST UPDATED:** 30/10/2017

JOB NUMBER      CLIENT      ADDRESS

Date Identified	Location of ACM	Type	Friable / Non-Friable	Quantity	Condition	Assessment / Action
26/10/2017	Electrical meter board	ACM	Non-friable	0.5 sqm	Good/Stable	Protect the retained ACM from damage during the course of the works
26/10/2017	Roof space	Asbestos cement sheet	Non-friable	Unknown	Broken pieced Damaged	Remove and dispose of the ACM