

ASBESTOS REGISTER

SITE: 7755 Quince 3 Shepherd Street, Maroubra

LAST UPDATED: 29/03/2017

JOB NUMBER CLIENT ADDRESS

Date Identified	Location of ACM	Type	Friable / Non-Friable	Quantity	Condition	Assessment / Action
07/07/2016	Gable ends	Asbestos cement sheet	Non-friable	15 sqm	Good/stable	Remove and dispose of the ACM as part of the contract works
07/07/2016	Study	Asbestos cement sheet	Non-friable	2.4 sqm	Good/stable	Remove and dispose of the ACM as part of the contract works
07/07/2016	Bathroom	Asbestos cement sheet	Non-friable	Unknown	Good/stable	Protect the retained ACM from damage during the course of the works
07/07/2016	Laundry	Asbestos cement sheet	Non-friable	1.3 sqm	Good/stable	Remove and dispose of the ACM as part of the contract works
07/07/2016	Electrical meter board	Asbestos cement sheet	Non-friable	Unknown	Good/stable	Protect the retained ACM from damage during the course of the works