

# ASBESTOS REGISTER

**SITE:** 7882 Lee.Clements 294 Rainbow Street, Coogee

**LAST UPDATED:** 16/10/2017

JOB NUMBER CLIENT ADDRESS

Date Identified	Location of ACM	Type	Friable / Non-Friable	Quantity	Condition	Assessment / Action
13/10/2017	Rear external wall cladding	Asbestos cement sheet	Non-friable	13 sqm	Good/Stable Surface coated to the exposed areas	To be removed by Cape Cod as part of the contract works
13/10/2017	Eave soffit lining (Gable end)	Asbestos cement sheet	Non-friable	1.5 sqm	Good/Stable Surface coated to the exposed areas	Protect the retained ACM from damage during the course of the works
13/10/2017	Gable end cladding	Asbestos cement sheet	Non-friable	4 sqm	Good/Stable Surface coated to the exposed areas	Protect the retained ACM from damage during the course of the works
13/10/2017	Front verandah soffit lining	Asbestos cement sheet	Non-friable	5.5 sqm	Good/Stable Surface coated to the exposed areas	Protect the retained ACM from damage during the course of the works
13/10/2017	Rear verandah cladding and privacy wall	Asbestos cement sheet	Non-friable	3.5 sqm	Good/Stable Surface coated to the exposed areas	Protect the retained ACM from damage during the course of the works

## ASBESTOS REGISTER

13/10/2017	Laundry wall and ceiling lining	Asbestos cement sheet	Non-friable	9.5 sqm	Good/Stable Surface coated to the exposed areas	To be removed by Cape Cod as part of the contract works
13/10/2017	Bathroom wall and ceiling lining	Asbestos cement sheet	Non-friable	6 sqm	Good/Stable Surface coated to the exposed areas	To be removed by Cape Cod as part of the contract works