

ASBESTOS REGISTER

SITE: 7868 Martins 406 Avoca Street, Kingsford

LAST UPDATED: 05/09/2017

JOB NUMBER CLIENT ADDRESS

Date Identified	Location of ACM	Type	Friable / Non-Friable	Quantity	Condition	Assessment / Action
04/09/2017	Eave soffit lining	Asbestos cement sheet	Non-friable	16 sqm	Good/Stable Surface coated to the exposed areas	Protect the retained ACM from damage during the course of the works
04/09/2017	Front porch soffit lining	Asbestos cement sheet	Non-friable	17.5 sqm	Good/Stable Surface coated to the exposed areas	Protect the retained ACM from damage during the course of the works
04/09/2017	Garage ceiling lining	Asbestos cement sheet	Non-friable	15 sqm	Good/Stable Surface coated to the exposed areas	Protect the retained ACM from damage during the course of the works