

# ASBESTOS REGISTER

**SITE:** 7732 Martin.Bower 12 Banks Street, Ashfield

**LAST UPDATED:** 28/03/2017

JOB NUMBER CLIENT ADDRESS

Date Identified	Location of ACM	Type	Friable / Non-Friable	Quantity	Condition	Assessment / Action
05/05/2016	Exterior cladding	Asbestos cement sheet	Non-friable	6 sqm	Good/stable	Remove and dispose of the ACM as part of the contract works
05/05/2016	Eave soffit lining	Asbestos cement sheet	Non-friable	2.1 sqm	Good/stable	Remove and dispose of the ACM as part of the contract works
05/05/2016	Laundry	Asbestos cement ceiling	Non-friable	10 sqm	Good/stable	Remove and dispose of the ACM as part of the contract works
05/05/2016	WC	Asbestos cement ceiling	Non-friable	2 sqm	Good/stable	Remove and dispose of the ACM as part of the contract works