

ASBESTOS REGISTER

SITE: 7792 Bradbery.Brandes De Roos 1 Chircan Street, Old Toongabbie

LAST UPDATED: 23/02/2017

JOB NUMBER CLIENT ADDRESS

| Date Identified | Location of ACM | Type | Friable / Non-Friable | Quantity | Condition | Assessment / Action |
|-----------------|------------------------|-----------------------|-----------------------|----------|-------------|-----------------------------------------------------------------------|
| 08/11/2016 | Bathroom | Asbestos cement sheet | Non-friable | 2.4sqm | Good/stable | Remove and dispose of the ACM as part of the contract works |
| 08/11/2016 | WC | Asbestos cement sheet | Non-friable | Unknown | Good/stable | Protect and retain the ACM from damage during the course of the works |
| 08/11/2016 | Laundry | Asbestos cement sheet | Non-friable | Unknown | Good/stable | Protect and retain the ACM from damage during the course of the works |
| 08/11/2016 | Electrical meter board | Asbestos cement sheet | Non-friable | Unknown | Good/stable | Protect and retain the ACM from damage during the course of the works |
| 08/11/2016 | Carport | Asbestos cement sheet | Non-friable | Unknown | Good/stable | Protect and retain the ACM from damage during the course of the works |