

ASBESTOS REGISTER

SITE: 7779 Oliver.Wright 217A Burns Bay Road, Lane Cove

LAST UPDATED: 10/02/2017

JOB NUMBER CLIENT ADDRESS

Date Identified	Location of ACM	Type	Friable / Non-Friable	Quantity	Condition	Assessment / Action
20/10/2016	Ensuite (shown as WIR on Construction drawing 3 of 8)	Asbestos cement wall lining	Non-friable	4.8sqm	Good/stable	Remove and dispose of the sheeting as part of the Contract works
20/10/2016	Eave soffit lining	Asbestos cement sheet	Non-friable	Unknown	Good/stable	Protect and retain from damage during the course of the works
20/10/2016	Front porch	Asbestos cement sheet	Non-friable	Unknown	Good/stable	Protect and retain from damage during the course of the works
20/10/2016	Bathroom	Asbestos cement wall lining	Non-friable	Unknown	Good/stable	Protect and retain from damage during the course of the works
20/10/2016	WC	Asbestos cement wall lining	Non-friable	Unknown	Good/stable	Protect and retain from damage during the course of the works
20/10/2016	Electrical meter board	Asbestos cement	Non-friable	Unknown	Good/stable	Protect and retain from damage during the course of the works