

ASBESTOS REGISTER



SITE: 7823 Tsakissiris.Gadge 6 The Causeway, Maroubra

LAST UPDATED: 02/08/2017

JOB NUMBER CLIENT ADDRESS

Date Identified	Location of ACM	Type	Friable / Non-Friable	Quantity	Condition	Assessment / Action
27/07/2017	Eave soffit lining	Asbestos cement sheet	Non-friable	5.5 sqm	Good/Stable Surface coated to the exposed areas	1 sqm to be removed by Cape Cod as part of the contract works. Protect the retained ACM from damage during the course of the works
27/07/2017	Weatherboard cladding	Asbestos cement sheet	Non-friable	12 sqm	Good/Stable Surface coated to the exposed areas	To be removed by Cape Cod as part of the contract works
27/07/2017	Backyard privacy screens	Asbestos cement sheet	Non-friable	7 sqm	Good/Stable Surface coated to the exposed areas	Protect the retained ACM from damage during the course of the works
27/07/2017	Living room ceiling lining	Asbestos cement sheet	Non-friable	17.5 sqm	Good/Stable Surface coated to the exposed areas	To be removed by Cape Cod as part of the contract works
27/07/2017	Disused ceiling mounted hot water system	Asbestos cement sheet	Non-friable	Unknown	Unknown	Remove and dispose of the disused hot water system