

ASBESTOS REGISTER



SITE: 7886 Hasson 11A Peel Street, Dover Heights

LAST UPDATED: 12/10/2017

JOB NUMBER CLIENT ADDRESS

Date Identified	Location of ACM	Type	Friable / Non-Friable	Quantity	Condition	Assessment / Action
10/10/2017	Eave soffit lining	Asbestos cement sheet	Non-friable	7 sqm	Good/Stable Surface coated to the exposed areas	4.5 sqm to be removed by Cape Cod as part of the contract works. Protect the retained ACM from damage during the course of the works
10/10/2017	Porch soffit lining	Asbestos cement sheet	Non-friable	1 sqm	Good/Stable Surface coated to the exposed areas	Protect the retained ACM from damage during the course of the works
10/10/2017	Malthoid sarking to underside roof tiles	ACM	Non-friable	35 sqm	Good/Stable	Remove and dispose of the ACM