

ASBESTOS REGISTER

SITE: 7731 Smith 66 Oberon Street, Randwick

LAST UPDATED: 29/03/2017

JOB NUMBER CLIENT ADDRESS

Date Identified	Location of ACM	Type	Friable / Non-Friable	Quantity	Condition	Assessment / Action
07/07/2016	Eave soffit lining	Asbestos cement sheet	Non-friable	6.7 sqm	Good/stable	Protect the retained ACM from damage during the course of the works
07/07/2016	Carport	Asbestos cement sheet	Non-friable	7.3 sqm	Good/stable	Remove and dispose of the ACM as part of the contract works