

# ASBESTOS REGISTER



**SITE:** 7817 Langan 10 Garden Street, Maroubra

**LAST UPDATED:** 11/09/2017

JOB NUMBER CLIENT ADDRESS

Date Identified	Location of ACM	Type	Friable / Non-Friable	Quantity	Condition	Assessment / Action
05/09/2017	Eave soffit lining	Asbestos cement sheet	Non-friable	14 sqm	Good/Stable Surface coated to the exposed areas	8 sqm to be removed by Cape Cod as part of the contract works  Protect the retained ACM from damage during the course of the works