

ASBESTOS REGISTER

SITE: 7742 Correa 26 Peacock Parade, Frenchs Forest

LAST UPDATED: 22/03/2017

JOB NUMBER CLIENT ADDRESS

Date Identified	Location of ACM	Type	Friable / Non-Friable	Quantity	Condition	Assessment / Action
31/05/2016	Eave soffit lining	Asbestos cement sheet	Non-friable	12.6 sqm	Good/stable	Remove and dispose of the ACM as part of the contract works
31/05/2016	Gable ends	Asbestos cement sheet	Non-friable	9 sqm	Good/stable	Remove and dispose of the ACM as part of the contract works
31/05/2016	Front porch	Asbestos cement sheet	Non-friable	Unknown	Good/stable	Protect and retain ACM from damage during the course of the works
31/05/2016	Lounge	Asbestos cement sheet	Non-friable	Unknown	Good/stable	Protect and retain ACM from damage during the course of the works
31/05/2016	Bathroom	Asbestos cement sheet	Non-friable	Unknown	Good/stable	Protect and retain ACM from damage during the course of the works
31/05/2016	WC	Asbestos cement sheet	Non-friable	Unknown	Good/stable	Protect and retain ACM from damage during the course of the works

ASBESTOS REGISTER

31/05/2016	Kitchen	Asbestos cement sheet	Non-friable	Unknown	Good/stable	Protect and retain ACM from damage during the course of the works
31/05/2016	Laundry	Asbestos cement sheet	Non-friable	Unknown	Good/stable	Protect and retain ACM from damage during the course of the works
31/05/2016	Electrical meter board	Asbestos cement sheet	Non-friable	Unknown	Good/stable	Protect and retain ACM from damage during the course of the works
31/05/2016	Garage	Asbestos cement sheet	Non-friable	Unknown	Good/stable	Protect and retain ACM from damage during the course of the works