

# ASBESTOS REGISTER

**SITE:** 7615 Sneddon 14d Dudley Street, Randwick

**LAST UPDATED:** 29/03/2017

JOB NUMBER CLIENT ADDRESS

Date Identified	Location of ACM	Type	Friable / Non-Friable	Quantity	Condition	Assessment / Action
10/07/2015	Cladding	Asbestos cement sheet	Non-friable	5 sqm	Good/stable	Remove and dispose of the ACM as part of the contract works
10/07/2015	Eave soffit lining	Asbestos cement sheet	Non-friable	7.2 sqm	Good/stable	Remove and dispose of the ACM as part of the contract works
10/07/2015	Pitched roof cavity	Malthoid sarking	Non-friable	20 sqm	Good/stable	Remove and dispose of the ACM as part of the contract works