

ASBESTOS REGISTER

SITE: 7837 Amland 7 Beach Road, Vacluse

LAST UPDATED: 02/08/2017

JOB NUMBER CLIENT ADDRESS

Date Identified	Location of ACM	Type	Friable / Non-Friable	Quantity	Condition	Assessment / Action
28/07/2017	Eave soffit lining	Asbestos cement sheet	Non-friable	16 sqm	Good/Stable Surface coated to the exposed areas	5.5 sqm to be removed by Cape Cod as part of the contract works. Protect the retained ACM from damage during the course of the works
28/07/2017	Front porch balustrade wall (internal)	Asbestos cement sheet	Non-friable	2.5 sqm	Good/Stable Surface coated to the exposed areas	To be removed by Cape Cod as part of the contract works
28/07/2017	Front balcony balustrade wall (internal)	Asbestos cement sheet	Non-friable	3.25 sqm	Good/Stable Surface coated to the exposed areas	To be removed by Cape Cod as part of the contract works
28/07/2017	Front balcony soffit lining	Asbestos cement sheet	Non-friable	16 sqm	Good/Stable Surface coated to the exposed areas	Protect the retained ACM from damage during the course of the works
28/07/2017	Carport soffit lining	Asbestos cement sheet	Non-friable	40 sqm	Good/Stable Surface coated to the exposed areas	Protect the retained ACM from damage during the course of the works