

# ASBESTOS REGISTER

**SITE:** 7798 Finnegan.Reilly 34 Heydon Street, Enfield

**LAST UPDATED:** 23/02/2017

JOB NUMBER CLIENT ADDRESS

Date Identified	Location of ACM	Type	Friable / Non-Friable	Quantity	Condition	Assessment / Action
02/02/2017	Eave soffit lining	Asbestos cement sheet	Non-friable	4.5 sqm	Good/stable Painted	Remove and dispose as part of the contract works
02/02/2017	Laundry ceiling lining	Asbestos cement sheet	Non-friable	4 sqm	Good/stable Painted	Protect the retained ACM from damage during the course of the works
02/02/2017	WC ceiling lining	Asbestos cement sheet cladding	Non-friable	2.4 sqm	Good/stable Painted	Protect the retained ACM from damage during the course of the works