

ASBESTOS REGISTER

SITE: 7848 Kawalsky 50 George Street, Dover Heights

LAST UPDATED: 03/08/2017

JOB NUMBER CLIENT ADDRESS

Date Identified	Location of ACM	Type	Friable / Non-Friable	Quantity	Condition	Assessment / Action
01/08/2017	Sunroom infill panel above window	Asbestos cement sheet	Non-friable	2.5 sqm	Good/Stable Surface coated to the exposed areas	Protect the retained ACM from damage during the course of the works
01/08/2017	Gable end cladding	Asbestos cement sheet	Non-friable	10 sqm	Good/Stable Surface coated to the exposed areas	Protect the retained ACM from damage during the course of the works