

ASBESTOS REGISTER

SITE: 7828 Gamerov 9 Kobada Road, Dover Heights

LAST UPDATED: 27/06/2017

JOB NUMBER CLIENT ADDRESS

Date Identified	Location of ACM	Type	Friable / Non-Friable	Quantity	Condition	Assessment / Action
05/05/2017	Front porch soffit lining	Asbestos cement sheet	Non-friable	2 sqm	Good/stable Painted	Remove and dispose of the ACM as part of the contract works
05/05/2017	Study ceiling lining	Asbestos cement sheet	Non-friable	7.6 sqm	Good/stable Painted	Remove and dispose of the ACM as part of the contract works Removed 26/06/2017
05/05/2017	Laundry ceiling lining	Asbestos cement sheet	Non-friable	4.5 sqm	Good/stable Painted	Protect and retain the ACM from damage during the course of the works
05/05/2017	Bathroom wall lining	Asbestos cement sheet	Non-friable	4 sqm	Good/stable Painted	Remove and dispose of the ACM as part of the contract works
05/05/2017	Electrical meter board	ACM	Non-friable	0.25 sqm	Good/stable	Remove and dispose of the ACM as part of the contract works