

ASBESTOS REGISTER

SITE: 7861 McCormack 82 Bridge Street, Lane Cove

LAST UPDATED: 06/09/2017

JOB NUMBER CLIENT ADDRESS

Date Identified	Location of ACM	Type	Friable / Non-Friable	Quantity	Condition	Assessment / Action
04/09/2017	Eave soffit lining	Asbestos cement sheet	Non-friable	19 sqm	Good/Stable Surface coated to the exposed areas	Protect the retained ACM from damage during the course of the works
04/09/2017	Carport ceiling lining	Asbestos cement sheet	Non-friable	16.5 sqm	Good/Stable Surface coated to the exposed areas	To be completely removed by Cape Cod as part of the contract works
04/09/2017	Disused ceiling mounted hot water system	ACM	Non-friable	Unknown	Unknown	Remove and dispose of the disused hot water system