

ASBESTOS REGISTER

SITE: 7767 Taumoefolau.Momsen 83 Formosa Street, Drummoyne

LAST UPDATED: 23/02/2017

JOB NUMBER CLIENT ADDRESS

Date Identified	Location of ACM	Type	Friable / Non-Friable	Quantity	Condition	Assessment / Action
03/08/2016	Laundry	Asbestos cement lining	Non-friable	Unknown	Good/stable	Protect the retained wall lining from damage during the course of the works
03/08/2016	Bathroom	Asbestos cement lining	Non-friable	1 sqm	Good/stable	Remove and dispose of the ACM sheeting as part of the contract works