

ASBESTOS REGISTER

SITE: 7835 Abood 3 Baglin Street, Bronte

LAST UPDATED: 13/06/2017

JOB NUMBER CLIENT ADDRESS

Date Identified	Location of ACM	Type	Friable / Non-Friable	Quantity	Condition	Assessment / Action
07/06/2017	Gable end cladding (front and side)	Asbestos cement sheet	Non-friable	8.5 sqm	Good/Stable Painted	Protect the retained ACM from damage during the course of the works
07/06/2017	Front porch soffit lining	Asbestos cement sheet	Non-friable	5 sqm	Some cracks in the sheet Painted	Protect the retained ACM from damage during the course of the works