

ASBESTOS REGISTER

SITE: 7605 Strang 44 Newcastle Street, Rose Bay

LAST UPDATED: 29/03/2017

JOB NUMBER CLIENT ADDRESS

Date Identified	Location of ACM	Type	Friable / Non-Friable	Quantity	Condition	Assessment / Action
21/05/2015	Eave soffit lining	Fibre cement sheet	Non-friable	4 sqm	Good/stable	Remove and dispose of the ACM as part of the contract works
21/05/2015	Rear patio	Fibre cement sheet	Non-friable	10 sqm	Good/stable	Remove and dispose of the ACM as part of the contract works
21/05/2015	Shower/WC	Fibre cement sheet	Non-friable	16 sqm	Good/stable	Remove and dispose of the ACM as part of the contract works
21/05/2015	Pitched roof cavity	Asbestos insulation in storage tank	Non-friable	Unknown	Good/stable	Remove and dispose of the tank as part of the contract works
21/05/2015	Carport	Asbestos cement sheet	Non-friable	2 sqm	Good/stable	Remove and dispose of the ACM as part of the contract works