

ASBESTOS REGISTER

SITE: 7824 Freeman 1 Captain Pipers Road, Vaucluse

LAST UPDATED: 08/05/2017

JOB NUMBER CLIENT ADDRESS

Date Identified	Location of ACM	Type	Friable / Non-Friable	Quantity	Condition	Assessment / Action
05/05/2017	Eave soffit lining	Asbestos cement sheet	Non-friable	14 sqm	Good/stable Painted	Protect and retain ACM from damage during the course of the works
05/05/2017	Shower and laundry flooring	Asbestos cement sheet	Non-friable	12 sqm	Good/stable	Remove and dispose of the ACM as part of the contract works. Protect the retained ACM from damage during the course of the works
05/05/2017	Front porch soffit lining	Asbestos cement sheet	Non-friable	1 sqm	Good/stable Painted	Protect and retain ACM from damage during the course of the works
05/05/2017	Kitchen infill lining – above sliding door	Asbestos cement sheet	Non-friable	2 sqm	Good/stable Painted	Remove and dispose of the ACM as part of the contract works.
05/05/2017	Neighbouring granny flat gable end cladding	Asbestos cement sheet	Non-friable	2.5 sqm	Damaged	Protect and retain ACM from damage during the course of the works

ASBESTOS REGISTER

05/05/2017	Electrical meter board	ACM	Non-friable	0.25 sqm	Good/stable	Protect and retain ACM from damage during the course of the works
05/05/2017	Under floor space – laundry and shower area	Asbestos cement sheet	Non-friable	Unknown	Broken pieces/damaged	Remove and dispose of the ACM as part of the contract works.