

ASBESTOS REGISTER

SITE: 7819 Adams 1 Rickard Avenue, Bondi Beach

LAST UPDATED: 13/11/2017

JOB NUMBER CLIENT ADDRESS

Date Identified	Location of ACM	Type	Friable / Non-Friable	Quantity	Condition	Assessment / Action
12/11/2017	Gable end cladding	Asbestos cement sheet	Non-friable	4.5 sqm	Good/Stable Surface coated to the exposed areas	Protect the retained ACM from damage during the course of the works
12/11/2017	Garage external cladding	Asbestos cement sheet and weatherboard cladding	Non-friable	40 sqm	Good/Stable Exposed sheeting to the inside	Protect the retained ACM from damage during the course of the works
12/11/2017	Kitchen floor covering adhesive	ACM floor adhesive	Non-friable	7.5 sqm	Good/Stable	To be removed by Cape Cod as part of the contract works