

ASBESTOS REGISTER

SITE: 7783 Lyons 17 Salisbury Street, Waverley

LAST UPDATED: 23/02/2017

JOB NUMBER CLIENT ADDRESS

Date Identified	Location of ACM	Type	Friable / Non-Friable	Quantity	Condition	Assessment / Action
04/11/2016	Exterior cladding	Asbestos cement weatherboard cladding	Non-friable	13.5 sqm	Good/stable	Remove and dispose of the ACM weatherboard as part of the contract works
04/11/2016	Eave soffit lining	Asbestos cement sheet	Non-friable	1.5 sqm	Good/stable	Remove and dispose of the ACM as part of the contract works
04/11/2016	External staircase	Asbestos cement sheet	Non-friable	Unknown	Good/stable	Protect the retained eaves from damage during the course of the works
04/11/2016	Rear patio	Asbestos cement sheet	Non-friable	Unknown	Good/stable	Protect the retained soffit lining from damage during the course of the works
04/11/2016	Shower	Asbestos cement wall lining, tiled to skirting level	Non-friable	Unknown	Good/stable	Protect the retained ACM from damage during the course of the works