

ASBESTOS REGISTER

SITE: 7880 Buchanan 4 Matthews Avenue, Lane Cove

LAST UPDATED: 12/10/2017

JOB NUMBER CLIENT ADDRESS

Date Identified	Location of ACM	Type	Friable / Non-Friable	Quantity	Condition	Assessment / Action
10/10/2017	Gable end cladding	Asbestos cement sheet	Non-friable	4.5 sqm	Good/Stable Surface coated to the exposed areas	To be removed by Cape Cod as part of the contract works