

ASBESTOS REGISTER

SITE: 7774 Sheehy 17 Brook Street, Coogee

LAST UPDATED: 23/02/2017

JOB NUMBER CLIENT ADDRESS

Date Identified	Location of ACM	Type	Friable / Non-Friable	Quantity	Condition	Assessment / Action
04/11/2016	Exterior cladding	Asbestos cement sheet	Non-friable	5.5 sqm	Good/stable	Remove and dispose of the ACM as part of the contract works
04/11/2016	Front porch	Asbestos cement sheet	Non-friable	Unknown	Good/stable	Protect the retained ACM from damage during the course of the works
04/11/2016	Laundry	Asbestos cement sheet	Non-friable	Unknown	Good/stable	Protect the retained ACM from damage during the course of the works
04/11/2016	Pitched roof cavity	Malthoid sarking	Non-friable	Unknown	Good/stable	Remove and dispose of the ACM as part of the contract works