

ASBESTOS REGISTER

SITE: 7780 Hill 75 Renwick Street, Drummoyne

LAST UPDATED: 23/02/2017

JOB NUMBER CLIENT ADDRESS

Date Identified	Location of ACM	Type	Friable / Non-Friable	Quantity	Condition	Assessment / Action
08/11/2016	Exterior cladding	Asbestos cement shingles	Non-friable	0.8 sqm	Good/stable	Remove and dispose of the ACM as part of the contract works
08/11/2016	Eave soffit lining	Asbestos cement sheet	Non-friable	0.9 sqm	Good/stable	Remove and dispose of the ACM as part of the contract works
08/11/2016	WC	Asbestos cement sheet	Non-friable	Unknown	Good/stable	Protect the retained ACM from damage during the course of the works
08/11/2016	Laundry	Asbestos cement sheet	Non-friable	Unknown	Good/stable	Protect the retained ACM from damage during the course of the works
08/11/2016	Pitched roof cavity	Malthoid sarking	Non-friable	Unknown	Good/stable	Remove and dispose of the malthoid sarking as part of the contract works