

ASBESTOS REGISTER

SITE: 7836 Hughes 41 Midelton Avenue. North Bondi

LAST UPDATED: 13/06/2017

JOB NUMBER CLIENT ADDRESS

Date Identified	Location of ACM	Type	Friable / Non-Friable	Quantity	Condition	Assessment / Action
06/06/2017	External cladding above rear awning	Asbestos cement sheet	Non-friable	2.5 sqm	Good/Stable Painted	Protect the retained ACM from damage during the course of the works
06/06/2017	Front porch soffit lining (front section)	Asbestos cement sheet	Non-friable	1 sqm	Good/Stable Painted	Protect the retained ACM from damage during the course of the works
06/06/2017	Laundry ceiling lining	Asbestos cement sheet	Non-friable	2.25 sqm	Good/Stable Painted	Protect the retained ACM from damage during the course of the works
06/06/2017	Living Room Fireplace Chimney internal lining	Asbestos cement sheet	Non-friable	4.5 sqm	Good/Stable Painted	Protect the retained ACM from damage during the course of the works
06/06/2017	Granny flat weatherboard cladding	Asbestos cement sheet	Non-friable	12 sqm	Good/Stable Painted	Protect the retained ACM from damage during the course of the works

ASBESTOS REGISTER

06/06/2017	Granny flat ceiling lining	Asbestos cement sheet	Non-friable	8 sqm	Good/Stable Painted	Protect the retained ACM from damage during the course of the works
06/06/2017	Granny flat bathroom wall lining	Asbestos cement sheet	Non-friable	14.5 sqm	Good/Stable Painted	Protect the retained ACM from damage during the course of the works
06/06/2017	Shed weatherboard cladding	Asbestos cement cladding	Non-friable	9 sqm	Good/Stable Painted	Protect the retained ACM from damage during the course of the works
06/06/2017	Disused ceiling mounted hot water system	ACM	Non-friable	Unknown	Good/Stable Painted	Remove and dispose of the disused hot water system
06/06/2017	Rear side and back boundary fence	Asbestos cement sheet	Non-friable	15 sqm	Good/Stable Painted	Protect the retained ACM from damage during the course of the works