

ASBESTOS REGISTER

SITE: 7830 Ip.Leung 93 Austin Street, Lane Cove

LAST UPDATED: 13/06/2017

JOB NUMBER CLIENT ADDRESS

Date Identified	Location of ACM	Type	Friable / Non-Friable	Quantity	Condition	Assessment / Action
08/06/2017	Eave soffit lining	Asbestos cement sheet	Non-friable	13.5 sqm	Good/Stable Painted	2.5 sqm to be removed by Cape Cod as part of the contract works. Protect the retained ACM from damage during the course of the works
08/06/2017	Kitchen alcove cladding	Asbestos cement weatherboards	Non-friable	7.5 sqm	Good/Stable Painted	Protect the retained ACM from damage during the course of the works
08/06/2017	Kitchen alcove wall and ceiling lining	Asbestos cement sheet	Non-friable	3.5 sqm	Good/Stable Painted	Protect the retained ACM from damage during the course of the works
08/06/2017	Linen cupboards ceiling lining	Asbestos cement sheet	Non-friable	0.5 sqm	Good/Stable Painted	Protect the retained ACM from damage during the course of the works
08/06/2017	Store ceiling lining	Asbestos cement sheet	Non-friable	6 sqm	Good/Stable Painted	Protect the retained ACM from damage during the course of the works

ASBESTOS REGISTER

08/06/2017	Store floor vinyl floor tiles	ACM backing	Non-friable	6 sqm	Good/Stable Painted	Protect the retained ACM from damage during the course of the works
08/06/2017	Disused ceiling mounted hot water system	ACM	Non-friable	Unknown	Unknown	Remove and dispose of the disused hot water system