

ASBESTOS REGISTER

SITE: 7814 Martin.Grace 72 Simpson Street, Bondi Beach NSW

LAST UPDATED: 07/06/2017

JOB NUMBER CLIENT ADDRESS

Date Identified	Location of ACM	Type	Friable / Non-Friable	Quantity	Condition	Assessment / Action
01/06/2017	Eave soffit lining (rear elevation)	Asbestos cement sheet	Non-friable	1.5 sqm	Good/Stable Painted	To be removed by Cape Cod as part of the contract works
01/06/2017	Front patio and entry soffit lining	Asbestos cement sheet	Non-friable	5 sqm	Good/Stable Painted	Protect the retained ACM from damage during the course of the works
01/06/2017	Bathroom wall lining	Asbestos cement sheet	Non-friable	3 sqm	Good/Stable Painted	To be removed by Cape Cod as part of the contract works
01/06/2017	Rear neighbouring shed (back fence)	Asbestos cement sheet cladding and cover battens	Non-friable	12 sqm	Damaged. Not painted or sealed	Protect the retained ACM from damage during the course of the works