

# ASBESTOS REGISTER

**SITE:** 7720 Antonopoulos.Selim 15 Eulabah Avenue, Earlwood

**LAST UPDATED:** 21/03/2017

JOB NUMBER CLIENT ADDRESS

Date Identified	Location of ACM	Type	Friable / Non-Friable	Quantity	Condition	Assessment / Action
03/05/2016	Eave soffit lining	Asbestos cement sheet	Non-friable	Unknown	Good/stable	Protect and retain ACM from damage during the course of the works
03/05/2016	Laundry	Asbestos cement sheet	Non-friable	3 sqm	Good/stable	Remove and dispose of the ACM as part of the contract works