

ASBESTOS REGISTER

SITE: 7666 Eadie.Smit-Eadie 45 Baker Street, Oatley

LAST UPDATED: 19/04/2017

JOB NUMBER CLIENT ADDRESS

Date Identified	Location of ACM	Type	Friable / Non-Friable	Quantity	Condition	Assessment / Action
02/09/2015	Exterior cladding	Asbestos cement cladding	Non-friable	5 sqm	Good/stable	Remove and dispose of the ACM as part of the contract works
02/09/2015	Eave soffit lining	Asbestos cement sheet	Non-friable	5 sqm	Good/stable	Remove and dispose of the ACM as part of the contract works
02/09/2015	Front verandah	Asbestos cement sheet	Non-friable	Unknown	Good/stable	Protect and retain the ACM from damage during the course of the works
02/09/2015	Laundry	Asbestos cement sheet	Non-friable	Unknown	Good/stable	Protect and retain the ACM from damage during the course of the works
02/09/2015	WC	Asbestos cement ceiling lining	Non-friable	Unknown	Good/stable	Protect and retain the ACM from damage during the course of the works
12/04/2017	External pipe	Asbestos cement piping	Non-friable	Unknown	Good/stable	Removed a 100mm round, 2.7m long pipe 18/04/2017