

ASBESTOS REGISTER

SITE: 7795 Kanaan 23 Auburn Street, Hunters Hill

LAST UPDATED: 24/07/2017

JOB NUMBER CLIENT ADDRESS

Date Identified	Location of ACM	Type	Friable / Non-Friable	Quantity	Condition	Assessment / Action
18/07/2017	Gable end cladding	Asbestos cement sheet	Non-friable	24 sqm	Good/Stable Surface coated to the exposed areas	13.5 sqm to be removed by Cape Cod as part of the contract works. Protect the retained ACM during the course of the works
18/07/2017	Side fences (both sides)	Asbestos cement sheet	Non-friable	30 sqm	Good/Stable	Protect the retained ACM during the course of the works