

ASBESTOS REGISTER

SITE: 7797 O'Shannassy.Cattana 70 Nancy Street, North Bondi

LAST UPDATED: 20/02/2017

JOB NUMBER CLIENT ADDRESS

Date Identified	Location of ACM	Type	Friable / Non-Friable	Quantity	Condition	Assessment / Action
17/02/2017	Porch soffit lining	Asbestos cement sheet	Non-friable	1.5sqm	Good/stable Painted	Protect the retained ACM from damage during the course of the works
17/02/2017	Shed	Asbestos cement sheet cladding	Non-friable	12sqm	Good/stable Painted	Protect the retained ACM from damage during the course of the works