

ASBESTOS REGISTER

SITE: 7889 Woodward 97 Tenterden Road, Botany

LAST UPDATED: 06/11/2017

JOB NUMBER CLIENT ADDRESS

Date Identified	Location of ACM	Type	Friable / Non-Friable	Quantity	Condition	Assessment / Action
03/11/2017	Eave soffit lining	Asbestos cement sheet	Non-friable	20.5 sqm	Good/Stable Surface coated to the exposed areas	2.5 sqm to be removed by Cape Cod as part of the contract works. Protect the retained ACM from damage during the course of the works
03/11/2017	Gable end cladding	Asbestos cement sheet	Non-friable	3.5 sqm	Good/Stable Surface coated to the exposed areas	Protect the retained ACM from damage during the course of the works
03/11/2017	Front verandah soffit lining and infill panels	Asbestos cement sheet	Non-friable	5.5 sqm	Good/Stable Surface coated to the exposed areas	Protect the retained ACM from damage during the course of the works
03/11/2017	Garage wall cladding	Asbestos cement sheet	Non-friable	38.5 sqm	Good/Stable Surface coated to the exposed areas	Protect the retained ACM from damage during the course of the works
03/11/2017	Garage gable end cladding	Asbestos cement sheet	Non-friable	3 sqm	Good/Stable Surface coated to the exposed areas	Protect the retained ACM from damage during the course of the works

ASBESTOS REGISTER

03/11/2017	Garage eave soffit lining cladding	Asbestos cement sheet	Non-friable	5 sqm	Good/Stable Surface coated to the exposed areas	Protect the retained ACM from damage during the course of the works
03/11/2017	Electrical meter board	ACM	Non-friable	0.5 sqm	Good/Stable	Protect the retained ACM from damage during the course of the works