

# ASBESTOS REGISTER

**SITE:** 7718      Choi      15 Sutherland Street, Lane Cove

**LAST UPDATED:** 22/03/2017

JOB NUMBER      CLIENT      ADDRESS

Date Identified	Location of ACM	Type	Friable / Non-Friable	Quantity	Condition	Assessment / Action
11/03/2015	Eave soffit lining	Asbestos cement sheet	Non-friable	5 sqm	Good/stable	Remove and dispose of the ACM as part of the contract works
11/03/2015	Front porch	Asbestos cement sheet	Non-friable	2.4 sqm	Good/stable	Remove and dispose of the ACM as part of the contract works
11/03/2015	Electrical meter board	Asbestos cement sheet	Non-friable	Unknown	Good/stable	Protect and retain ACM from damage during the course of the works