

ASBESTOS REGISTER

SITE: 7772 Erlich.Marsh 51 Onslow Street, Rose Bay

LAST UPDATED: 23/03/2017

JOB NUMBER CLIENT ADDRESS

Date Identified	Location of ACM	Type	Friable / Non-Friable	Quantity	Condition	Assessment / Action
07/09/2016	Exterior cladding, bargeboard of store room	Asbestos cement sheet	Non-friable	1.5 sqm	Good/stable	Remove and dispose of the ACM as part of the contract works
07/09/2016	Eave soffit lining, bargeboard outside kitchen	Asbestos cement sheet	Non-friable	1 sqm	Good/stable	Remove and dispose of the ACM as part of the contract works
07/09/2016	Gable end lining	Asbestos cement sheet	Non-friable	Unknown	Good/stable	Protect and retain the ACM from damage during the course of the works
07/09/2016	Front porch	Asbestos cement sheet	Non-friable	Unknown	Good/stable	Protect and retain the ACM from damage during the course of the works
07/09/2016	Laundry	Asbestos cement sheet	Non-friable	2.4 sqm	Good/stable	Remove and dispose of the ACM as part of the contract works
07/09/2016	Shower	Asbestos cement sheet	Non-friable	2.4 sqm	Good/stable	Remove and dispose of the ACM as part of the contract works

ASBESTOS REGISTER

07/09/2016	Store	Asbestos cement sheet	Non-friable	Unknown	Good/stable	Protect and retain the ACM from damage during the course of the works
07/09/2016	Electrical meter board	Asbestos cement sheet	Non-friable	Unknown	Good/stable	Protect and retain the ACM from damage during the course of the works