

# ASBESTOS REGISTER

**SITE:** 7854 Yeates.Halloran 2 Walker Street, Canada Bay

**LAST UPDATED:** 19/07/2017

JOB NUMBER CLIENT ADDRESS

Date Identified	Location of ACM	Type	Friable / Non-Friable	Quantity	Condition	Assessment / Action
17/07/2017	Eave soffit lining	Asbestos cement sheet	Non-friable	3 sqm	Good/Stable Surface coated to the exposed areas	2 sqm to be removed by Cape Cod as part of the contract works. Protect the retained ACM from damage during the course of the works
17/07/2017	Gable end cladding	Asbestos cement sheet	Non-friable	1 sqm	Good/Stable Surface coated to the exposed areas	Protect the retained ACM from damage during the course of the works
17/07/2017	Front porch soffit lining	Asbestos cement sheet	Non-friable	6 sqm	Good/Stable Surface coated to the exposed areas	To be removed by Cape Cod as part of the contract works
17/07/2017	Manhole cover	Asbestos cement sheet	Non-friable	0.25 sqm	Good/Stable Surface coated to the exposed areas	To be removed by Cape Cod as part of the contract works