

ASBESTOS REGISTER

SITE: 7649 Malcolm.Miles 204 Whale Beach Road, Whale Beach

LAST UPDATED: 27/03/2017

JOB NUMBER CLIENT ADDRESS

Date Identified	Location of ACM	Type	Friable / Non-Friable	Quantity	Condition	Assessment / Action
05/08/2015	Eave soffit lining	Asbestos cement sheet	Non-friable	13 sqm	Good/stable	Remove and dispose of ACM as part of the contract works
05/08/2015	Ensuite	Asbestos cement sheet wall linings	Non-friable	Unknown	Good/stable	Ensuite to be completely stripped and all plumbing/drainage terminated. Walls to be made good as part of the contract works