

ASBESTOS REGISTER

SITE: 7771 Ilencik.Sampson 31 Knowles Avenue, North Bondi

LAST UPDATED: 08/03/2017

JOB NUMBER CLIENT ADDRESS

Date Identified	Location of ACM	Type	Friable / Non-Friable	Quantity	Condition	Assessment / Action
15/12/2016	Cladding above the rear elevation windows	Asbestos cement sheet	Non-friable	2.5 sqm	Stable/deteriorating surface coating	To be removed as part of the contract works
15/12/2016	Neighbouring rear property garage	Asbestos cement sheet	Non-friable	5 sqm	Good/stable Painted	Protect and retain the ACM from damage during the course of the works