

# ASBESTOS REGISTER

**SITE:** 7702 Bury 3 Warragal Road, Turramurra

**LAST UPDATED:** 22/03/2017

JOB NUMBER CLIENT ADDRESS

Date Identified	Location of ACM	Type	Friable / Non-Friable	Quantity	Condition	Assessment / Action
22/02/2016	Eave soffit lining	Asbestos cement sheet with pvc cover strips	Non-friable	Unknown	Good/stable	Protect and retained ACM from damage during the course of the works
22/02/2016	Front verandah	Asbestos cement sheet with pvc cover strips	Non-friable	Unknown	Good/stable	Protect and retained ACM from damage during the course of the works
22/02/2016	Rear verandah	Asbestos cement sheet with pvc cover strips	Non-friable	Unknown	Good/stable	Protect and retained ACM from damage during the course of the works
22/02/2016	Electrical meter board	Asbestos cement sheet	Non-friable	1 sqm	Good/stable	Remove and dispose of the ACM as part of the contract works