

# ASBESTOS REGISTER

**SITE:** 7815 Burt 25 Carrington Street, North Strathfield

**LAST UPDATED:** 02/05/2017

JOB NUMBER CLIENT ADDRESS

Date Identified	Location of ACM	Type	Friable / Non-Friable	Quantity	Condition	Assessment / Action
28/04/2017	Garage cladding	Asbestos cement sheet	Non-friable	50.5 sqm	Good/stable Painted	Protect the retained ACM from damage during the course of the works
28/04/2017	Study external wall lining	Asbestos cement sheet	Non-friable	7.5 sqm	Good/stable Painted	Protect the retained ACM from damage during the course of the works
28/04/2017	Ground floor gable end cladding	Asbestos cement sheet	Non-friable	2.25 sqm	Good/stable Painted	Protect the retained ACM from damage during the course of the works
28/04/2017	Roofing shingles above front bay window (outside study)	Asbestos cement sheet	Non-friable	0.5 sqm	Good/stable Painted	Protect the retained ACM from damage during the course of the works