

ASBESTOS REGISTER

SITE: 7879 Ritchie 16 Windsor Road, Willoughby

LAST UPDATED: 04/12/2017

JOB NUMBER CLIENT ADDRESS

Date Identified	Location of ACM	Type	Friable / Non-Friable	Quantity	Condition	Assessment / Action
30/11/2017	Gable end cladding (Ground floor)	Asbestos cement sheet	Non-friable	11 sqm	Good/Stable Surface coated to the exposed areas	Protect the retained ACM from damage during the course of the works
30/11/2017	Front porch soffit lining and infill panels	Asbestos cement sheet	Non-friable	17 sqm	Good/Stable Surface coated to the exposed areas	Protect the retained ACM from damage during the course of the works
30/11/2017	Side verandah soffit lining	Asbestos cement sheet	Non-friable	20 sqm	Some broken sheets Surface coated to the exposed areas	To be removed by Cape Cod as part of the contract works
30/11/2017	Laundry wall lining	Asbestos cement sheet	Non-friable	10 sqm	Good/Stable Surface coated to the exposed areas	Protect the retained ACM from damage during the course of the works