

ASBESTOS REGISTER

SITE: 7776 Kavka.Milecki 3 Rickard Avenue, Bondi Beach

LAST UPDATED: 14/11/2017

JOB NUMBER CLIENT ADDRESS

Date Identified	Location of ACM	Type	Friable / Non-Friable	Quantity	Condition	Assessment / Action
12/11/2017	Gable end cladding	Asbestos cement sheet	Non-friable	4.5 sqm	Good/Stable Surface coated to the exposed areas	Protect the retained ACM from damage during the course of the works
12/11/2017	Outside laundry cladding and lining	Asbestos cement sheet	Non-friable	15.5 sqm	Some broken sheets Not sealed	Protect the retained ACM from damage during the course of the works
12/11/2017	Next door garage wall lining (side fence)	Asbestos cement sheet	Non-friable	5 sqm	Some broken sheets Not sealed	Protect the retained ACM from damage during the course of the works
12/11/2017	Electrical meter board (above cabinet)	Asbestos cement sheet	Non-friable	1 sqm	Good/Stable Surface coated to the exposed areas	Protect the retained ACM from damage during the course of the works