

ASBESTOS REGISTER

SITE: 7833 Meyers.Bryant 22a Wood Street, Lane Cove West

LAST UPDATED: 14/09/2017

JOB NUMBER CLIENT ADDRESS

Date Identified	Location of ACM	Type	Friable / Non-Friable	Quantity	Condition	Assessment / Action
13/09/2017	Eave soffit lining	Asbestos cement sheet	Non-friable	15.5 sqm	Good/Stable Surface coated to the exposed areas	Protect the retained ACM from damage during the course of the works
13/09/2017	Laundry wall lining	Asbestos cement sheet	Non-friable	3 sqm	Good/Stable Surface coated to the exposed areas	Protect the retained ACM from damage during the course of the works
13/09/2017	Disused ceiling mounted hot water system	ACM	Non-friable	Unknown	Unknown	Remove and dispose of the disused hot water system with ACM