

ASBESTOS REGISTER

SITE: 7777 McEvoy 28 Alt Street, Queens Park

LAST UPDATED: 20/02/2017

JOB NUMBER CLIENT ADDRESS

Date Identified	Location of ACM	Type	Friable / Non-Friable	Quantity	Condition	Assessment / Action
23/11/2016	Cladding	Asbestos cement sheet	Non-friable	2.5sqm	Good/stable	Remove and dispose of the ACM sheeting as part of the Contract works
23/11/2016	Eave soffit lining	Asbestos cement sheet	Non-friable	2.25sqm	Good/stable	Remove and dispose of the ACM sheeting as part of the Contract works
23/11/2016	Gable end lining	Asbestos cement sheet	Non-friable	Unknown	Good/stable	Protect and retain the ACM sheeting from damage during the course of the works
23/11/2016	Electrical meter board	Asbestos cement sheet cladding	Non-friable	Unknown	Good/stable	Protect and retain the ACM sheeting from damage during the course of the works