

ASBESTOS REGISTER

SITE: 7788 Foley 16 Kaneruka Place, Baulkham Hills

LAST UPDATED: 06/10/2017

JOB NUMBER CLIENT ADDRESS

Date Identified	Location of ACM	Type	Friable / Non-Friable	Quantity	Condition	Assessment / Action
20/01/2017	Eave soffit lining	Asbestos cement sheet	Non-friable	21 sqm	Good/stable Painted	21 sqm removed as part of the contract works 06/10/2017
20/01/2017	Gable end lining	Asbestos cement sheet cladding	Non-friable	6 sqm	Good/stable Painted	6 sqm removed as part of the contract works 06/10/2017
20/01/2017	Front verandah soffit lining	Asbestos cement sheet cladding	Non-friable	9 sqm	Good/stable Painted	9 sqm removed as part of the contract works 06/10/2017
20/01/2017	Bathroom walls	Asbestos cement sheet cladding	Non-friable	4 sqm	Good/stable Painted	Protect and retain ACM from damage during the course of the works
20/01/2017	Electrical meter board	ACM back board	Non-friable	0.5 sqm	Good/stable	Protect and retain ACM from damage during the course of the works