

ASBESTOS REGISTER

SITE: 7885 De Vlieger 28 Dargan Street, Naremburn

LAST UPDATED: 08/12/2017

JOB NUMBER CLIENT ADDRESS

Date Identified	Location of ACM	Type	Friable / Non-Friable	Quantity	Condition	Assessment / Action
06/12/2017	Gable end cladding	Asbestos cement sheet	Non-friable	12 sqm	Good/Stable Surface coated to the exposed areas	Protect the retained ACM from damage during the course of the works
06/12/2017	Front porch soffit lining	Asbestos cement sheet	Non-friable	10 sqm	Good/Stable Surface coated to the exposed areas	Protect the retained ACM from damage during the course of the works
06/12/2017	Ensuite wall lining behind tiles	Asbestos cement sheet	Non-friable	5 sqm	Good/Stable Surface coated to the exposed areas	Protect the retained ACM from damage during the course of the works