

ASBESTOS REGISTER

SITE: 7747 Luzar 21 Ramsay Avenue, West Pymble

LAST UPDATED: 02/03/2017

JOB NUMBER CLIENT ADDRESS

Date Identified	Location of ACM	Type	Friable / Non-Friable	Quantity	Condition	Assessment / Action
27/07/2016	Eave soffit lining	Asbestos cement sheet	Non-friable	Unknown	Good/stable	Protect and retain the ACM from damage during the course of the works
27/07/2016	Front patio	Asbestos cement sheet	Non-friable	Unknown	Good/stable	Protect and retain the ACM from damage during the course of the works
27/07/2016	Rear deck	Asbestos cement sheet	Non-friable	Unknown	Good/stable	Protect and retain the ACM from damage during the course of the works
27/07/2016	Electrical meter board	Asbestos cement sheet	Non-friable	Unknown	Good/stable	Protect and retain the ACM from damage during the course of the works
27/07/2016	Garage - back wall	Asbestos cement sheet	Non-friable	Unknown	Good/stable	Protect and retain the ACM from damage during the course of the works 9 sqm removed 01/03/2017

ASBESTOS REGISTER

						9 sqm removed 02/03/2017
--	--	--	--	--	--	--------------------------